

File

REPUBLIC OF THE PHILIPPINES
ORMOC CITY
Office of the Municipal Board

EXCERPT FROM THE MINUTES OF THE SPECIAL SESSION HELD BY THE MUNICIPAL
BOARD OF ORMOC CITY, PHILIPPINES, IN ITS SESSION HALL ON SEPTEMBER 4,
1951.

PRESENT:

Hon. Lucilo A. Conui	-----	Presiding Officer
Hon. Marcelo D. Sandalan	-----	Vice Mayor
Hon. Guillermo T. Parrilla	-----	City Councilor
Hon. Felipe Adolfo	-----	"
Hon. Cleto P. Evangelista	-----	"
Hon. Flaviano Montesclaros	-----	"
Hon. Porfirio Ayuyao	-----	"

ABSENT:

Hon. Victorino C. Teleron	-----	"
Hon. Pablo D. Pajaron	-----	"
Hon. Antonio C. Cataag	-----	"

RESOLUTION NO. 128

Letter of the City Engineer, Ormoc City dated August 13, 1951
and letter of the City Health Officer, dated August 13, 1951, here-
under quoted verbatim respectively as follows:

REPUBLIC OF THE PHILIPPINES
ORMOC CITY
Office of the City Engineer

August 13, 1951

The Honorable City Board
Thru the Hon. City Mayor
Ormoc City

I am urgently requesting and recommending for your kind
consideration and approval to appropriate P2,000 aid for the urgent
repairs of the Ormoc Puericulture Center which is noted to have the
following defects:

1. The pitch of the roofing is too low and not applicable
for the present aluminium roofing.
2. Due to leakages in various portions of the two wings from
the roof and gutters, the roof girts, ceiling boards and
other portions affected by this leakages become rotten and
liable to fall.

In order to remedy the above defects, the roof framing has
to be remodeled to make the pitch higher by changing the trusses
and corrugated G.I. sheets. The toilet also has to be remodeled
by modifying the septic tank following the recommendation by the
City Health Officer. The tank needs outlet for discharge of excess
water.

It is urgently reiterated and hoped that the above request be
given immediate action and approval by that Honorable Body, delay of
which might cause the building to fall down.

Very respectfully,

(Sgd.) FERNANDO C. MONTE
City Engineer

(over)