

REPUBLIC OF THE PHILIPPINES
MUNICIPAL BOARD
ORMOC CITY
Office of the Secretary

EXCERPTS FROM THE MINUTES OF THE SPECIAL SESSION OF THE MUNICIPAL
BOARD OF ORMOC CITY, PHILIPPINES, HELD IN ITS SESSION HALL ON
NOVEMBER 27, 1957

PRESENT:

His Honor, Acting City Mayor Esteban C. Conejos, Presiding
Hon. Rafael M. Mejia, Acting Vice Mayor, Ex-Officio Member
Hon. Emilio C. Penserga, City Councilor
Hon. Guillermo T. Parrilla, City Councilor
Hon. Jorge P. Tan, Jr., City Councilor
Hon. Alvaro I. Gutierrez City Councilor
Hon. Teotimo P. Ocubillo, City Councilor
Hon. Marciano S. Du, City Councilor

ABSENT:

Hon. Itaki Larrazabal, City Councilor
Hon. Guillermo T. Parrilla, City Councilor
Hon. Cesar Samson, City Councilor

RESOLUTION NO. 223

"WHEREAS, in connection with the request of the Manager, Ormoc Sugar Company, this City, and pursuant to paragraph (r) of Section 15, Republic Act 179, otherwise known as the Charter of Ormoc City, this Board caused the inspection of the boilers of the Ormoc Sugar Company at Ipil, Ormoc City, and for this purpose, authorized Engineer Jovenal Z. Gonzales, Machinery Inspector of the Bureau of Public Highways, to inspect the boilers of the said company;

"WHEREAS, Engr. Gonzales made two inspections on the said boilers wherein he noted in his first inspection some defects which he embodied in his report to this Board after said inspection;

"WHEREAS, last November 25th, 1957, Engr. Gonzales made another inspection on the said boilers and the following is his report and recommendation:

"November 25, 1957

The Municipal Board
Ormoc City

S i r s :

In connection with the defects of the OSCO boilers noted by the undersigned in his safety inspection of the said boilers, another inspection was made last Friday afternoon to check on the stated defects.

It is informed that the defects stated in the Recommendations - Items 1 to 4, inclusive - were already corrected. Item 5, which calls for the provision of safe catwalks can not be done yet on Boiler No. 6 as the brickworks is not complete to date. However, the plan for the installation of the said boiler includes a correspondingly adequate catwalk. Boilers Nos. 1, 4 and 5 have already existing catwalks, but the company is reconditioning them in conjunction with the new building plans.

In view thereof, immediate approval of the permit for operation of the said boilers is highly recommended.

Very truly yours,

(SGD) JOVENAL Z. GONZALES
Machinery Inspector"

- Page 2 -
(RESOLUTION NO. 223, SERIES 1957 - MUNICIPAL BOARD,
ORMOC CITY)

"WHEREAS, in view of the above recommendation and in the interest of public welfare, this Body is convinced that the Ormoc Sugar Company boilers are fit and safe for operation.


"NOW, THEREFORE, the Board, on motion of Councilor Gutierrez, seconded by Councilor Tan, Jr., and Vice Mayor Mejia;

WRRESOLVED, as it is hereby resolved, to declare as this Body hereby declares the existing boilers of the Ormoc Sugar Company fit and safe for operation, and do hereby recommend the approval of their permit for operation, basing on the above recommendation of Machinery Inspector Jovenal Z. Gonzales;


"RESOLVED FINALLY, to furnish copies of this resolution each to the Honorable City Mayor, the City Engineer, the City Treasurer, all of Ormoc City; and the Manager, Ormoc Sugar Company, Ipil, Ormoc City.

"CARRIED UNANIMOUSLY."


I HEREBY CERTIFY to the correctness of the above-quoted resolution.


RAMON BANTASAN
Secretary

APPROVED:


ESTEBAN C. CONESOS
Acting City Mayor
Presiding Officer

ATTESTED:


LUCAS DE LOYOLA
Secretary to the City Mayor

/ibl.